

Sub Divisional Level Water Testing Laboratory

**UTTARAKHAND JAL SANSTHAN
HALDWANI, NAINITAL**

Name of the Customer/ Organization:	Mallikarjun School Bohrakun-Bhimtal Nainital 263136.	Sample Description	Mallikarjun School Bohrakun-Bhimtal Nainital.
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis	25-03-2025
Sample Code:	MSB-47	Sample collected By	Customer
Sample Receiving Date and Time:	25.03.2025 10.40 Am	Date of Issue Report	28-03-2025


Water Quality Test Report

Testing Details

S.N.	Parameters	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Results
1	Colour (Hazen units)	5	15	05
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.41
4	Alkalinity as CaCo ₃ (mg/l)	200	600	106
5	Turbidity (NTU)	1	5	0.84
6	Total dissolved solid (mg/l)	500	2000	184
7	Chloride (mg/l)	250	1000	3.9
8	Total hardness (mg/l)	200	600	120
9	Calcium(as ca) (mg/l)	75	200	38.4
10	Magnesium (mg/l)	30	100	5.8
11	Total coliform (MPN/100ML)*	Absent	Absent	ABSENT
12	E.Coli (MPN/100ML)*	Absent	Absent	ABSENT

CHEMIST,
SDLWQTML,

UJS Haldwani (Nainital)


PRINCIPAL

**MALLIKARJUN SCHOOL
BHIMTAL (NAINITAL)**

****END OF REPORT****

Technical Manager In- charge of lab
UJS Haldwani (Nainital)

TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)



उत्तराखण्ड जल संस्थान

Water Works Haldwani

दिनांक

28/03/2025

WH13443205

13443205

O-WH/6285

मांग पत्रिका सं०

O-WH/6285

बिल की अवधि से

तक

श्री/श्रीमती

Mallikarjun School

पता

Bhimtal

माह

जल मूल्य	जल कर	सीवर कर	सीवर सीट	अन्य प्राप्ति	जमा राशि (रु०)
0.00		0.00		1160.00	1,160.00

बिल सं०

O-WH/6285/32

दिनांक

28-03-2025

को रिबेट राशि

जमा राशि

1,160.00

Cash

द्वारा प्राप्त हुई

शब्दों में

ONE THOUSAND ONE HUNDRED SIXTY

बकाया राशि

0.00

वरिष्ठ लेखाधिकारी

अधिकृत हस्ताक्षरकर्ता

नोट : चैक द्वारा भुगतान की दशा में जारी रसीद चैक कैश होने पर ही वैध होगी।

रेवन्यू स्टैम्प